

REGISTRATION APPROVAL

Thursday, September 22, 2011
United Filtration Systems, Inc.
6558 Diplomat Drive
Sterling Heights, MI 48314
www.unitedfiltration.com

ATTENTION: Henryk Fisher

Our File : 8619 [0 F


With reference to your submission respecting the registration of the item below, for legal use in the province, please note we have surveyed, approved and registered this design as noted.

MANUFACTURER : Headline Filters Limited	
CATALOG OR DRAWING : PVE-4714-1.0 Rev. 0	
ITEM : Series 360A Compressed Air Filters	CRN : OE14569.53

We wish to point out that every fitting must be constructed strictly in accordance with the registered design.

Fitting registrations are required to be resubmitted for validation after ten (10) years from the registration date in accordance with CSA B51, Clause 4.2.1. The date of expiry for this registration is Jun 15, 2021

Sincerely,



Kalam Azad, P.Eng.

Codes and Standards Compliance

REMARKS: CRN registered under reciprocal agreement. Valid quality management system must be maintained for the fitting registration to remain valid until the expiry date.

Headline Filters Ltd.

Drawing List and Scope of Registration 360A Series

Design Data:

Code: ASME VIII-1 2010 Edition
 Design Pressure: 500 psi @ 248 °F
 Hydrotest: 773 psi @ 70 °F
 MDMT: -325 °F
 Impact Testing: Exempt per UNF-65
 Corrosion Allowance: None
 Radiography: None

Drawing List

Drawing Number	Description
HF4/1317	243A-3520 GA
HF4/3537	360-3520 1/4" NPT Head
HF4/0681/1	245A Bowl
HF4/1318	245A-3520 GA
HF4/3538	360-3520 1/2" NPT Head
HF4/0681/1	245A Bowl
HF4/2375	223A-3520 GA
HF4/3538	360-3520 1/2" NPT Head
HF/0678/1	225A Bowl
HF4/1703	225A-3520 GA
HF4/3538	360-3520 1/2" NPT Head
HF4/0678/1	225A Bowl
HF4/1627	360A-3520 GA
HF4/3537	360-3520 1/4" NPT Head
HF4/0679/1	230A Bowl
HF4/1537	365-3520 GA
HF4/3538	360-3520 1/2" NPT Head
HF4/0679/1	230A Bowl
HF4/3543	370A-3520 GA
HF4/3538	360-3520 1/2" NPT Head
HF4/0682/1	250A Bowl

Technical Safety Authority of Saskatchewan Boiler & P.V. Safety Unit	
CRN	OE 14569-53
File	8619
REGISTERED	
Date	22 Sep 2011
Expires	15 Jun 2014
Design Survey Office	